1	2	3
8	Singur H.E.P.	2x7.5 Environmental clearance awaited. However, this project has been posed for availing German financial assistance.

Tripping of Northern Grid

969. DR. MURLI MANOHAR JOSHI:
SHRI TRILOKI NATH CHATURVEDI:

Will the Minister of POWER be pleased to state:

(a) whether Government have enquired into the massive power tripping in the northern grid in recent months; if so, the details thereof; and

(b) whether some State Governments have been overdrawing power and if so, what steps Government propose to take in this regard?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P.V. RANGAYYA NAIDU): (a) During recent months, there was one major northern grid disturbance on 15.1.94 at 0900 hours when lines emanating from 400 KV Kanpur-Panki sub-stattion tripped on fault. This resulted in power supply failure in parts of Delhi, Northern Rajasthan and U.P. While no Committee was constituted by the Govt., the matter was discussed and reasons for the failure gone into by the Northern Regional Electricity Board

(b) The details of entitlement/actual drawal from the Central Sector Stations in the Northern region during April-January, 1994 are given below:-

(Figures in million units)

Name of the State/System	Entitlement	Act. Drawal
Delhi	4649.4	4106.2
Haryana	2987.7	3875.7
Himachal Pradesh	677.7	378.2
Jammu & Kashmir	2296.2	1844.1
Punjab	3815.1	3433.1
Rajasthan	3701.5	4444.7
Uttar Pradesh	10686.7	10599.0
Chandigarh	175.3	144.1
Bihar	—	164.5 (Assistance no entitlement)
B.B.M.B.	—	0.0
Total	28989.6	28989.6

It will be seen from the above that only Haryana and Rajasthan have overdrawn. Both the SEBs have been advised to take appropriate load management steps to avoid overdrawal.

Power Breakdown due to fault in Northern Grid

970. SHRI KRISHNA KUMAR BIRLA: Will the Minister of POWER be pleased to state:

(a) whether the entire northern parts